## Product datasheet: Space heater to Regulation (EU) No 811/2013 (S.I. 2019 No. 539 / Programme 2)

| Manufacturer ST Heat source Low temperature heat pump   | 204778<br>TEBEL ELTRON<br>Außenluft |
|---|-------------------------------------|
| Heat source   |                                     |
|   | Außenluft                           |
| Low temperature heat numn   | . abemart                           |
|   |                                     |
| With auxiliary heater   | X                                   |
| Combination heater with heat pump   |                                     |
| Rated heating output under colder climate conditions for medium- temperature applications (P rated)  kW                                   | 19                                  |
| Rated heating output under average climate conditions for medium- temperature applications (P rated)                                      | 15                                  |
| Rated heating output under warmer climate conditions for medium-<br>temperature applications (P rated)                                    | 8                                   |
| Tj = -7 °C heating output, partial load range under colder climate conditions (Pdh)   | 11,6                                |
| Tj = -7 °C heating output, partial load range under average climate conditions (Pdh)  | 12,9                                |
| Tj = 2 °C heating output, partial load range under colder climate conditions (Pdh)  | 7,5                                 |
| Tj = 2 °C heating output, partial load range under average climate conditions (Pdh)   | 7,7                                 |
| Tj = 2 °C heating output, partial load range under warmer climate conditions (Pdh)  | 8,1                                 |
| Tj = 7 °C heating output, partial load range under colder climate conditions (Pdh)  | 8,6                                 |
| Tj = 7 °C heating output, partial load range under average climate conditions (Pdh)   | 8,5                                 |
| Tj = 7 °C heating output, partial load range under warmer climate conditions (Pdh)  | 8,0                                 |
| Tj = 12 °C heating output, partial load range under colder climate conditions (Pdh)   | 9,1                                 |
| Tj = 12 °C heating output, partial load range under average climate   | 9,7                                 |
| conditions (Pdh)  Tj = 12 °C heating output, partial load range under warmer climate  kW  | 9,0                                 |
| conditions (Pdh)  | 11.6                                |
| Tj = dual mode temperature under colder climate conditions (Pdh) kW  Tj = dual mode temperature under average climate conditions (Pdh) kW | 11,6                                |
|   | 12,9                                |
| Tj = dual mode temperature under warmer climate conditions (Pdh) kW   | 8,1                                 |
| Tj = operating temperature limit under colder climate conditions (Pdh) kW   | 9,7                                 |
| Tj = operating temperature limit under average climate conditions (Pdh) kW  | 12,4                                |
| Tj = operating temperature limit under warmer climate conditions (Pdh) kW   | 8,1                                 |
| Dual mode temperature under colder climate conditions (Tbiv)  C  Dual mode temperature under colder climate conditions (Tbiv)             | -7                                  |
| Dual mode temperature under average climate conditions (Tbiv)  C  C  C  C  C  C  C  C  C  C  C  C  C                                      | -7                                  |
| Dual mode temperature under warmer climate conditions (Tbiv)  Seasonal space heating energy efficiency under colder climate               | 2                                   |
| conditions for medium-temperature applications (ηs)   | 115                                 |
| Seasonal space heating energy efficiency under average climate conditions for medium-temperature applications (ηs)                        | 140                                 |
| Seasonal space heating energy efficiency under warmer climate conditions for medium-temperature applications (ηs)                         | 129                                 |
| Tj = -7 °C COP, partial load range under colder climate conditions (COPd)   | 2,69                                |
| Tj = -7 °C COP, partial load range under average climate conditions (COPd)  | 2,59                                |
| Tj = 2 °C COP, partial load range under colder climate conditions (COPd)  | 3,66                                |
| Tj = 2 °C COP, partial load range under average climate conditions (COPd)   | 3,54                                |
| Tj = 2 °C COP, partial load range under warmer climate conditions (COPd)  | 2,78                                |
| Tj = 7 °C COP, partial load range under colder climate conditions (COPd)  | 4,53                                |
| Tj = 7 °C COP, partial load range under average climate conditions (COPd)   | 4,49                                |
| Tj = 7 °C COP, partial load range under warmer climate conditions (COPd)  | 3,40                                |

| Tj = 12 °C COP, partial load range under colder climate conditions (COPd)                            |       | 4,91  |
|--|-------|---|
| Tj = 12 °C COP, partial load range under average climate conditions (COPd)                           |       | 5,39  |
| Tj = 12 °C COP, partial load range under warmer climate conditions (COPd)                            |       | 4,48  |
| Tj = dual mode temperature under colder climate conditions (COPd)                                    |       | 2,69  |
| Tj = dual mode temperature under average climate conditions (COPd)                                   |       | 2,59  |
| Tj = dual mode temperature under warmer climate conditions (COPd)                                    |       | 2,78  |
| Tj = operating temperature limit under colder climate conditions (COPd)                              |       | 1,85  |
| Tj = operating temperature limit under average climate conditions (COPd)                             |       | 2,39  |
| Tj = operating temperature limit under warmer climate conditions (COPd)                              |       | 2,78  |
| Operating temperature limit under colder climate conditions (TOL)                                    | °C    | -20   |
| Operating temperature limit under average climate conditions (TOL)                                   | °C    | -10   |
| Operating temperature limit under warmer climate conditions (TOL)                                    | °C    | 2   |
| Operating temperature limit of heating water under colder climate conditions (WTOL)                  | °C    | 65  |
| Operating temperature limit of heating water under average climate conditions (WTOL)                 | °C    | 65  |
| Operating temperature limit of heating water under warmer climate conditions (WTOL)                  | °C    | 65  |
| Power consumption, off-mode (Poff)   | W     | 53  |
| Power consumption, thermostat off-mode (PTO)   | W     | 69  |
| Power consumption, standby state (PSB)   | W     | 53  |
| Power consumption, operating state, with crankcase heating (PCK)                                     | W     | 0   |
| Rated heating output of auxiliary heater under colder climate conditions (PSUP)                      | kW    | 19,2  |
| Rated heating output of auxiliary heater under average climate conditions (PSUP)                     | kW    | 0,0   |
| Type of energy supply, auxiliary heater  |       | elektrisch  |
| Output control   |       | veränderlich  |
| Sound power level, outdoor   | dB(A) | 55  |
| Annual energy consumption under colder climate conditions for medium-temperature applications (QHE)  | kWh/a | 16095   |
| Annual energy consumption under average climate conditions for medium-temperature applications (QHE) | kWh/a | 8384  |
| Annual energy consumption under warmer climate conditions for medium-temperature applications (QHE)  | kWh/a | 3285  |
| Flow rate on heat source side  | m³/h  | 4000  |
| Special measures   |       | For all special measures to be taken during assembly, installation or maintenance of the room heater, see the installation instructions |