

Product datasheet: Mechanical ventilation unit to Regulation (EU) No. 1254/2014 | 1253/2014

		VRC-W 250 E Premium
		205086
Manufacturer		STIEBEL ELTRON
Specific energy consumption under colder climate conditions with control subject to on-site requirements	kWh/(m2a)	-77.1
Specific energy consumption under average climate conditions with control subject to on-site requirements	kWh/(m2a)	-40.6
Specific energy consumption under warmer climate conditions with control subject to on-site requirements	kWh/(m2a)	-17
Energy efficiency class under colder climate conditions with control subject to on-site requirements (A+ -> G)		A+
Energy efficiency class under average climate conditions with control subject to on-site requirements (A+ -> G)		A
Energy efficiency class under warmer climate conditions with control subject to on-site requirements (A+ -> G)		E
Ventilation unit type		WLA, Zwei Richtungen
Drive type		Drehzahl geregelt
Heat recovery type		Rekuperativ
Rate of temperature change for heat recovery	%	74.8
Max. air flow rate	m3/h	250
Max. power consumption	Watt	170
Sound power level LWA	dB(A)	54
Reference air flow rate	m3/s	0.1
Reference pressure differential	Pa	50
Specific power input	Wm3h	0.2
Control factor, control subject to on-site requirements		0,65
Internal air leakage quota	%	0.8
External air leakage quota	%	0.6
Mixing ratio		-
Internet address		www.stiebel-eltron.com
Sensitivity to pressure fluctuations		-
Airtightness between indoors and outdoors		-
Annual power consumption under colder climate conditions with control subject to on-site requirements	kWh/a	693
Annual power consumption under average climate conditions with control subject to on-site requirements	kWh/a	156
Annual power consumption under warmer climate conditions with control subject to on-site requirements	kWh/a	111
Annual heating savings under colder climate conditions with control subject to on-site requirements	kWh/a	8566
Annual heating savings under average climate conditions with control subject to on-site requirements	kWh/a	4379
Annual heating savings under warmer climate conditions with control subject to on-site requirements	kWh/a	1980